

## Elevator Life Safety List

*If the following items do not meet the requirements of the code during inspection, the inspector will not issue a certificate of operation.*

- Phone in elevator
- Phase I fire service
- Any safety device which is part of the safety string list under A17.1 – 2.26.2
- Door restrictors
- Bottom door guides (Door Gibs)
- Failure of Static test
- Failure of Emergency brake
- Suspension means has two unfavorable conditions
  - No weight testing will be performed