24.39.40 - SAFETY RULES FOR ELEVATORS, ESCALATORS, AND MOVING WALKS

000. LEGAL AUTHORITY.

This chapter is adopted by the administrator of the Division of Occupational Professional Licenses <u>pursuant to in accordance</u> with Sections 39-8605, 67-2604, 67-2614, 67-9409- and 67-9406 Idaho Code. (3-28-23)

001. SCOPE.

These rules govern the <u>operation</u>, <u>installation</u>, <u>alteration</u>, <u>design</u>, <u>construction</u>, <u>installation</u>, <u>operation</u>, <u>inspection</u>, <u>testing</u>, <u>maintenance</u>, <u>and alteration</u>, <u>or repair of conveyances. elevators</u>, <u>escalators</u>, <u>moving walks</u>, <u>platform lifts</u>, <u>material lifts</u>, and <u>dumbwaiters</u>.

002. ADOPTION AND INCORPORATION BY REFERENCE.

- **01. Documents.** The following codes, amendments, and updates are hereby adopted and incorporated by reference into these rules for all conveyances subject to this chapter. (3-28-23)
- a. ANSI/ASME A17.1 20162022, Safety Code for Elevators and Escalators with the following exceptions: (3-28-23)
- i. Compliance with section 2.8.3.3.2 requires that the means for disconnecting the main power, as required by this section, to be within sight of controller for all conveyances with an elevator machine room or control room. (3-28-23)
- ii. Compliance with section 8.11.2.1.5(c) Car and Counterweight Buffer testing must be conducted at slow speed in accordance with Item $5.9.2.1(\underline{ba})$ in ANSI/ASME A17.2 $\underline{20142020}$. (3-28-23)
- iii. Compliance with Section 2.2.2.5, which requires a sump pump or drain in the elevator pit, is optional. If a sump pump or drain is installed, it must meet the requirements of this section. A sump with a cover must be provided in each elevator pit. (3-28-23)

b.	ANSI/ASME A17.3 2015 Safety Code for Existing Elevators and Escalators.	(3-28-23)
c.	ANSI/ASME A17.4 1999-2015 Guide for Emergency Personnel.	(3-28-23)
d.	ANSI/ASME A17.5 20149 Elevator and Escalator Electrical Equipment.	(3-28-23)
e.	ANSI/ASME A17.6 2010 Standard for Elevator Suspension, and Governor Systems.	(3-28-23)
f.	ANSI/ASME A17.7 2012 Performance-based Safety Code for Elevators and Escalators.	(3-28-23)
g.	ANSI/ASME A17.8 2016-2021 Standard for Wind Tower Turbine Elevators.	(3-28-23)

- h. ICC/ANSI A117.1 2009 Accessible and Usable Buildings and Facilities. (3-28-23)
- i. ANSI/ASME A18.1 2014-2020 Safety Standards for Platform Lifts and Chairlifts. (3-28-23)
- **O2.** Copies. Copies of the codes, amendments, and updates listed in Subsection 004.01 of these rules are available for review at the Division of Building Safety Division of Occupational and Professional Licenses offices. (3-28-23)

ASME QE-1 2013-2018 Standard for the Qualification of Elevator Inspectors.

003. -- 010. (RESERVED)

011. INSPECTION REQUIREMENTS.

Commented [LK1]: Added Division Administrator authority.

Commented [LK2]: Changed to mirror 39-8605.

Commented [AL3]: Per GB, recommending staying with the 2015 version to limit regulatory burden

Commented [LK4]: Please be aware that all of these materials will be impacted by HB 563. Link to HB 563 is found born:

https://legislature.idaho.gov/sessioninfo/2024/legislation/H 0563/

Commented [LK5]: Will need to be renumbered for compliance with Division rule numbering system.

Commented [JT6]: Per Amanda

(3-28-23)

Commented [LK7]: HB 563 requires an agency to make incorporated material available on its website.

Section 000 Page 1 JScholer 09272023

Access. All machine rooms and spaces must be free of dirt and debris and have any obstacles to Commented [JT8]: Per Amanda access removed. (3-28-23)02. Technician on Site. An elevator technician and fire alarm technician must be present on site to restore elevator and fire alarm systems. (3-28-23)Installation. The elevator installation must be complete and safe for inspection. Equipment, components, or systems installed on the conveyance must function in accordance with design and code requirements. If equipment, components, or systems are installed that are not required by the currently adopted code, they must function properly or be removed. Inspection Fees. Inspection fees for elevators are assessed and collected according to the schedule listed in Section 39-8616, Idaho Code, except that reinspection fees for all types of conveyances is one hundred dollars (\$100) for the first hour of inspection, or portion thereof, and one hundred dollars (\$100) for each hour of inspection thereafter. Commented [LK9]: For compliance with Division Rule Numbering System, this needs to be moved to Rule 500. 012. APPROVAL OF NEW OR ALTERNATIVE TECHNOLOGY. Administrator-Approval Required. If, due to construction or technological impediments, an elevator or conveyance cannot comply with applicable code requirements, approval of new or alternative construction or technology may be requested from the administrator. Approval must be obtained before Commented [JT10]: Per Amanda 02. Submission Deadline. Details of the proposed construction or technology, including design, material specifications and calculations, and such other information as may be requested, must be submitted to the Commented [JT11]: Per Amanda administrator at least thirty (30) days in advance of the anticipated construction start date. The manufacturer of the new product or system must provide the administratordivision with an Accredited Elevator/Escalator Certification Organization (AECO) approval and certification in accordance with ANSI/ASME A17.7 Performance-based Safety Code for Elevators and Escalators or engineering and test data demonstrating that the proposed technology is safe for the intended purpose. The owner of the new product or system must provide the administrator with a document in which the owner acknowledges that the proposed technology is not governed by the applicable safety code and assures the administrator that, at such time as the code is revised to include the product or system, the owner will modify the product or system to bring it into compliance. The owner must assure the administrator that if the product or system Commented [JT12]: Per Amanda cannot be modified or altered to bring it into compliance with the applicable code it will be removed and replaced with code-compliant equipment. The manufacturer of the new product or system must provide training to Division personnel on the proposed technology and any related products or systems at no cost to the Division. Engineer Approval. The information provided in compliance with the foregoing requirements must be approved by an Accredited Elevator/Escalator Certification Organization (AECO) or a registered professional engineer experienced in elevator or conveyance design prior to submission to the administrator. (3-28-23)013. -- 999. (RESERVED)

Page 2

(3-28-23)

JScholer 09272023

For an inspection may to take place:

Section 000