

Site Plan PGLF Applicants (greater than 10,000 gallons)

(Complete this form and include with your application)

CONTAINER INFORMATION							
Container	Aboveground or Underground	Container Manufacturer	Water Capacity	Working Pressure	Year Manufactured	Serial #	ASME Code Symbol
1							
2							
3							
4							
5							
6							

NFPA 58 (2017)	CONTAINERS AND APPURTENANCES	Yes	No
5.9.4.2	Liquid & vapor openings fitted w/ internal valves equipped for remote closure and thermal activation.		
6.4.1	Separation distance from nearest important building.		ft
6.4.1	Separation distance from nearest line of adjoining property that can be built upon.		ft
6.4.1	Separation distance between containers.		ft
6.5.3.3	Separation distance from stored combustible materials.		ft
6.5.3.6	Separation distance from aboveground tanks containing liquids having flash points below 200°F.		ft
6.5.3.13	Separation distance from a vertical plane beneath overhead electrical power lines over 600 volts.		ft
6.8.1.2	Containers and systems protected from vehicular impact.	Yes	No
6.9.2	Pressure relief device installed to vent upward, away from container and unobstructed to the open air.	Yes	No
6.11.3.10	Piping supported and protected against physical damage	Yes	No
6.14	Emergency shutoff valves equipped on liquid and vapor transfer lines.	Yes	No
6.14.9	Incorporated means to actuate emergency shutoff valves in the event of a pull-away.	Yes	No
6.14.13	Emergency shutoff valves for railroad tank car transfer systems.	Yes	No
6.15	Hydrostatic relief valves installed in each section of piping in which liquid LP-Gas can be isolated.	Yes	No

NFPA 58 (2017)	POINT OF TRANSFER (point of transfer is measured from the end of the delivery hose)	Yes	No
Table 6.7.2.1 (A)	Separation distance from buildings with at least 1-hour fire-rated walls.		ft
Table 6.7.2.1 (B)	Separation distance from buildings with other than at least 1-hour fire-rated walls.		ft
Table 6.7.2.1 (C)	Separation distance from building wall openings or pits at or below the level of the point of transfer.		ft
Table 6.7.2.1 (D)	Separation distance from line of adjoining property that can be built upon.		ft
Table 6.7.2.1 (E)	Separation distance from outdoor places of public assembly.		ft
Table 6.7.2.1 (F)	Separation distance from public ways, including public streets, highways, thoroughfares, sidewalks.		ft
Table 6.7.2.1 (G)	Separation distance from driveways.		ft
Table 6.7.2.1 (H)	Separation distance from mainline railroad track centerlines.		ft
Table 6.7.2.1 (I)	Separation distance from containers other than those being filled.		ft
Table 6.7.2.1 (J)	Separation distance from flammable and Class II combustible liquid dispensers.		ft
Table 6.7.2.1 (K)	Separation distance from flammable and Class II AG containers & fill point of UG containers.		ft
6.13.4	Remote shutdown station for internal valves proximity to the liquid transfer point.		ft
6.13.4	Remote shutdown station in the path of egress from the liquid transfer point.	Yes	No
6.13.5	Remote shutdown station identified by a sign, visible from the point of transfer.	Yes	No
Table 6.25.2.2	Electrical equipment within 5 ft. approved for Class 1, Division 1, Group D.	Yes	No
Table 6.25.2.2	Electrical equipment beyond 5 ft. but within 15 ft. approved for Class 1, Division 2, Group D.	Yes	No

NFPA 58 (2017)	FIRE EXTINGUISHER	Yes	No
4.7 & 6.29.4.2	Dry chemical rating BC or ABC of at least 18lbs capacity.		lbs
	Tag or label proving annual inspection, maintenance, or recharging attached to the extinguisher.	Yes	No

Note: A "No" answer may not be disqualifying but may also require improvements before a license can be issued.